



PARAMETERS	
Duty point	bar
Pump Staging	bar
Differential	bar
Pump minimum run time	secs
Support delay	secs
Low pressure	bar
High pressure	bar
Low pressure delay	secs
High Pressure delay	secs

Item	Description	Part No./Type
CB1-2	Motor Circuit Breaker	SCB-100f/c
CF1-2	Contr Fuse T2A 20mm	RFA-100020
E1	Enclosure 425 x 425	SPP-106003
F1	Xformer Fuses 1. 1/4" 1A	SFC-120001
IP1	4 Ch Analogue Input	RPC-120103
IP2	4 Ch Level Sensing Input	RPC-120134
IP3	4 Ch Digital input module	RPC-120120
IS1	Interlocked Isolator	GHA-03xxxx
LWP1	Low Water Sensor	GSW-100000
PCB1	Interface Card	EPB-120134
PCB2	2020PLUS Controller	RPC-122002
PCB3	Keypad - 2 row	EPK-120012
PT1	Press. Transducer 392	GST-392100
RC1	Ribbon Cable 25 way	SWA-254250
TB1	Terminal Block	SJD-
TX1	Control Cct Transformer	RT3-060024

For Wire No.s/Colours see Work Instr. 05/103.

ISSUE	DESCRIPTION	APPD	DATE
6	Note added to Tank 2 low water level link. Transducer now 12.5 bar and part numbers updated	RB	7/11/08
7	Updated for V3.00 software with digital control	RB	3/3/11
8	Digital input module added (RPC-120120)	RB	3/10/11

AquaTech Pressmain

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT. UK
 Phone: (0)1206-215121 Fax: -215131
 Manchester Office: 130 Princess road, Manchester. M16 7BY. UK
 Phone: (0)161-226-4727 Fax: -226-5848

TITLE
 Aquatic water pressure booster set
 AMV2/HY2AV-E wiring diagram with 2020Plus
 control & BMS Enhanced package
 Inverter driven motors 230vac 1 Phase

DRAWN	APPROVED	DATE
IDT		15/02/99
DRWG No. A12042		