



Item	Description	Part No
AA1	Audible Alarm	SKA-101200
CF1/CF2	Control Fuse T2A 20mm	RFA-100020
F1	Transformer Mains fuse T1A x 1.25"	SFC-120001
IP1	4 Ch Analogue Input Module	RPC-120103
IP2	4 Ch Level Sensing Module	RPC-120134
IP3	4 Ch Digital Input Module (Non-Inv)	RPC-120120
IS1	Isolator	SHD-020121
PCB1	Interface Card	EPM-120031
PCB2	2020PLUS Controller	RPC-122002
PCB3	Keypad - 2 row	EPK-120012
PF1,PF2	Pump fuse T3.15/6.3A 20mm	RFA-100031/63
PT1	392 Pressure Transducer 0-12.5 bar	GST-392100
TX1	Transformer 230V /24V 50VA	RT2-050024
R1,R2	Optional Pump run volt frees (230vac)	SGE-240010
*TS1	Optional Tubular Heater Thermostat	SAH-224001
TS1	Optional Anti condensation Thermostat	SAH-224000
*PH1	Optional Tubular Panel Heater (120w)	SAH-124120
PH1	Optional Anti condensation panel heater (30w)	SAH-124030

\*Tubular heater only available for C1 Cabinet Enclosures

Display Parameters		
Duty point		bar
Pump Staging		bar
Differential		bar
Pump minimum run time		secs
Support delay		secs
Low pressure		bar
High pressure		bar
Low pressure delay		secs
High Pressure delay		secs

ISSUE	DESCRIPTION	APPD	DATE
12	Updated to suit revised audible alarm fitted to PCB1, 24vac cabling removed	RB	21/3/13
13	Motor cable labelling changed	RB	1/7/13
14	Low Level cable labelling changed from Black to Green	RWW	1/7/13

**AquaTech Pressmain**

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT. UK  
 Phone: (0)1206-215121 Fax: -215131

Manchester Office: 130 Princess road, Manchester. M16 7BY. UK  
 Phone: (0)161-226-4727 Fax: -226-5848

**TITLE** Aquapack pressurisation unit models: AP-3, AP-7, 2ET45-E & 2ET90-E  
 230vac 1 Phase wiring diagram with 2020Plus control & BMS Enhanced package

DRAWN	APPROVED	DATE
JPA		25/01/99
DRWG No.		<b>A12040</b>