



*Note 1: Use 0.75mm 3 core CY screened cable, earth screen at panel end only for wiring solenoid valves (where fitted)

Note 2: SV2 / SV3 only fitted for units with multiple spill valves

ISSUE	DESCRIPTION	APPD	DATE
9	Updated to show multiple spill valves (SV2 & SV3) where fitted	RB	3/6/11
10	SB3 Added	SAS	28/1/13
11	Updated to suit revised audible alarm fitted to PCB1	RB	11/4/13

AquaTech Pressmain

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT. UK
Phone: (0)1206-215121 Fax: -215131
Manchester Office: 130 Princess road, Manchester. M16 7BY. UK
Phone: (0)161-226-4727 Fax: -226-5848

TITLE
Heating system pressurisation unit wiring diagram for models:- SP2ET, AS2ET. AN2ET 230vac 1 Phase SA10-E, GV100-E, SB3 230vac 1 Phase 2020Plus models P4 & P7 <= 0.37 kw & BMS Enhanced package

DRAWN	APPROVED	DATE
JPA		23/11/99
DRWG No.		A12066