



Item	Description	Part No
AA1	Audible Alarm	SKA-001200
PCB1/F1,F2	Pump fuse T1A 20mm	RFA-100010
PCB4/F1	Mains fuse T1A 20mm	RFA-100010
PCB4/F2	Transformer Fuse T250mA 20mm	RFA-100002
PCB4/F3	Control Fuse T500mA 20mm	RFA-100005
IP1	4 Ch Analogue Input Module	RPC-120103
IP2	4 Ch Level Sensing Module	RPC-120134
IS1	Isolator	SHD-020121
PT1	392 Pressue Transducer 0-12.5 bar	GST-392109
MF1	Mains filter	SAS-124030
TM1, TM2	Pump Thermistor	SNT-200100
TX1	Transformer 230V /12V 6VA	RT2-020024
VDR1	Voltage dependent resistor	RHV-002750
PCB1	Mothercard	EPC-120022
PCB2	2020PLUS Controller	RPC-122002
PCB3	Keypad - 2 row	EPK-120012
PCB4	2ETM40-E POWER PCB	EPE-100000

The parameters can be viewed on the display

ISSUE	DESCRIPTION	APPD	DATE
9	updated for 2020+ V2.00 software	RB	11/03/08
10	Low and High level approach connections removed. Transducer now 12.5 bar and part numbers updated	RB	7/11/08
11	Wire link added between terminals 9 & 11	RB	6/2/09

AquaTech Pressmain

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT, UK
Phone: (0)1206-215121 Fax: -215131

Manchester Office: 130 Princess road, Manchester. M16 7BY, UK
Phone: (0)161-226-4727 Fax: -226-5848

TITLE **Micromatic Pressurisation unit 2ETM40-E 230vac 1 Phase wiring diagram with 2020Plus control & BMS Enhanced package**

DRAWN	APPROVED	DATE
JPA		29/4/98
DRWG No. A12028		