



PARAMETERS	
Duty point	bar
Pump Staging	bar
Differential	bar
Pump minimum run time	secs
Support delay	secs
Low pressure	bar
High pressure	bar
Low pressure delay	secs
High Pressure delay	secs

Item	Description	Part No./Type
CB1-4	Motor Circuit Breaker	MGC60HD1-fic
CF1-2	Control Fuse T2A 20mm	RFA-100020
E1	Enclosure 425 x 425	SPP-106003
F1	Xformer Fuses 1. 1/4" 1A	SFC-120001
IP1	4 Ch Analogue Input	RPC-120103
IP2	4 Ch Level Sensing Input	RPC-120134
IS1	Interlocked Isolator	GHA-03xxxx
LWP1	Low Water Sensor	GSW-100000
PCB1	Interface Card	EPB-120134
PCB2	2020PLUS Controller	RPC-122004
PCB3	Keypad - 4 row	EPK-120014
PT1	Press. Transducer 392	GST-392100
RC1	Ribbon Cable 25 way	SWA-254250
TB1	Terminal Block	SJD-
TX1	Control Cct Transformer	240/12/24V/50VA

For Wire No.s/Colours see Work Instr. 05/103.

ISSUE	DESCRIPTION	APPD	DATE
2	pump trips rewired for Bo-01 software	IDT	08/01
3	Updated for 2020+ V2.00 software. Note added to Tank 2 low water level link. Transducer now 12.5 bar and part numbers updated	RB	7/11/08
4	Updated for V3.00 software with digital control	RB	3/3/11

AquaTech Pressmain

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT. UK
Phone: (0)1206-215121 Fax: -215131

Manchester Office: 130 Princess road, Manchester. M16 7BY. UK
Phone: (0)161-226-4727 Fax: -226-5848

TITLE
Aquamatic water pressure booster set HY4AV-E wiring diagram with 2020Plus control & BMS Enhanced package Inverter driven motors 230vac 1 Phase

DRAWN	APPROVED	DATE
IDT		11/7/00
DRWG No. A12044		