



Item	Description	Part No./Type
E1	Enclosure 300x300x132	SPP-610303
F1	Mains Fuse T6.3Ax20mm	RFH-100063
F2, F3	24vdc Fuse T1Ax20mm	RFA-100010
LG1	LOGO Smart Relay	SGT-024104
PS1	LOGO Power Supply	SGT-024113
PB1	Push Button (momentary)	SGR-342100
AA1	Audible Alarm 24vdc	SKA-102401
SW1	Pumpset changeover switch	SHR-310001

Notes :
 Connect 24VDC to :
 I1 for Run pumpset 1 (hand signal)
 I2 for Run pumpset 2 (hand signal)
 I3 for Pumpset 1 not healthy (tripped)
 I4 for Pumpset 2 not healthy (tripped)
 I5 for mute audible alarm
 I6 for manual changeover

ISSUE	DESCRIPTION	APPD	DATE
2	Drawing number A12359 added to Pumpset 1 & 2 section to suit 2 off HY4AV 3 phase units	RB	27/3/07
3	Control panel box size increased	RB	21/3/13

Head Office: AGM House, London road, Copford, Colchester, Essex. CO6 1GT. UK
 Phone: (0)1206-215121 Fax: -215131

AquaTech Pressmain

Manchester Office: 130 Princess road, Manchester. M16 7BY. UK
 Phone: (0)161-226-4727 Fax: -226-5848

TITLE **Twin pumpset auto changeover panel "LG2P" (Via Smart relay controller)**

DRAWN	APPROVED	DATE
RB		20/10/04

DRWG No. **A11101**